

SECTION 08 32 19
SLIDING WOOD-FRAMED GLASS DOORS

SECTION 08 43 31
WOOD-FRAMED SLIDING GLASS STOREFRONTS

NOTE: Modify footers to align when using this section name and number.

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes furnishing and installing a wood framed single track, sliding glass or wood panel door, wall or storefront panel system that includes:
1. Wood frame
 2. Tracks
 3. Threshold
 4. Sliding panels
 5. Swing panels
 6. Stacking bays
 7. Sliding-swinging and locking hardware
 8. Weather stripping
 9. Glass and glazing
 10. Insect screens (optional)
 11. Accessories as required for a complete working installation
- B. Related Documents and Sections: Contractor to examine Contract Documents for requirements that directly affect or are affected by Work of this Section. A list of those Documents and Sections include, but is not limited to, the following:
1. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 General Requirements, Specification Sections, apply to this Section
 2. Section 06 10 00, Rough Carpentry: Wood framing R.O. and blocking
 3. Section 06 20 00, Finish Carpentry
 4. Section 07 27 00, Air Barriers: Building paper and buildingwrap
 5. Section 07 62 00, Sheet Metal Flashing and Trim: Flashing gutters, and other sheet metal work
 6. Section 07 90 00, Joint Protection
 7. Section 08 42 23, Glass Entrance Swing Doors
 8. Section 08 43 33, Wood Framed Folding Glass Storefronts: NanaWall WD65
 9. Section 08 43 33, Wood Framed Folding Glass Storefronts: NanaWall WD66
 10. Section 08 52 00, Wood Windows: NanaWall WD68, tilt-turn, casement window
 11. Section 09 22 16, Non-Structural Metal Framing: Metal framing R.O. and reinforcement
 12. Section 10 22 45, Wood Framed Sliding Glass Partitions: NanaWall HSW66

1.02 REFERENCES

- A. Reference Standards in accordance with Division 01 and current editions from the following:
1. AAMA. American Architectural Manufacturers Association; www.aamanet.org
 - a. AAMA 502, Voluntary Specification for Field Testing of Newly Installed Fenestration Products
 - b. AAMA 611, Voluntary Specification for Anodized Architectural Aluminum
 - c. AAMA 1304, Voluntary Specification for Forced Entry Resistance of Side-Hinged Door Systems
 - d. AAMA/WDMA/CSA 101/I.S.2/A440, NAFS, North American Fenestration Standard - Specification for Windows, Doors, and Skylights
 2. ANSI. American National Standards Institute; www.ansi.org
 - a. ANSI Z97.1, Safety Performance Specifications and Methods of Test for Safety Glazing Material Used in Buildings
 3. ASTM. ASTM International; www.astm.org
 - a. ASTM C1036, Standard Specification for Flat Glass
 - b. ASTM C1048, Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass
 - c. ASTM E283, Test Method for Rate of Air Leakage through Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference
 - d. ASTM E330, Test Method for Structural Performance of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference
 - e. ASTM E331, Standard Test Method for Water Penetration of Exterior Windows, Skylights, Doors, and Curtain Walls by Uniform Static Air Pressure Difference
 - f. ASTM E413, Classification for Rating Sound Insulation
 - g. ASTM E547, Test Method for Water Penetration of Exterior Windows, Curtain Walls, and Doors by Cyclic Static Air Pressure Differential
 - h. ASTM E1332, Standard Classification for Rating Outdoor-Indoor Sound Attenuation
 - i. ASTM E2068, Standard Test Method to Determine the Opening and Breakaway Forces of Sliding Windows and Doors
 - j. ASTM F842, Standard Test Methods for Measuring the Forced Entry Resistance of Sliding Door Assemblies, Excluding Glazing Impact
 4. CPSC. Consumer Product Safety Commission; www.cpsc.gov
 - a. CPSC 16CFR-1201, Safety Standard for Architectural Glazing Materials
 5. CSA Group (Canadian Standards Association); www.csagroup.org/global/en/home
 - a. CSA A440S1 - The Canadian supplement to North American (NAFS) standards
 6. Energy Star, U.S. Environmental Protection Agency (EPA) Program; www.energystar.gov
 7. NFRC. National Fenestration Rating Council; www.nfrc.org
 - a. NFRC 100, Procedure for Determining Fenestration Product U-factors
 - b. NFRC 200, Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence
 - c. NFRC 400, Procedure for Determining Fenestration Product Air Leakage
 - d. NFRC 500, Procedure for Determining Fenestration Product Condensation Resistance Rating Values

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate Sliding Glass Storefront system and framing R.O.
- B. Preinstallation Meetings: See Section 01 30 00.

1.04 SUBMITTALS

- A. For Contractor submittal procedures see Section 01 30 00.
- B. Product Data: Submit manufacturer's printed product literature for each Sliding Glass Storefront system to be incorporated into the Work. Show performance test results and details of construction relative to materials, dimensions of individual components, profiles, and colors.
- C. Product Drawings: Indicate Sliding Glass Storefront system component sizes, dimensions and framing R.O., configuration, sliding and swing panels, direction of swing, stacking layout, typical head jamb, side jambs and sill details, type of glazing material, handle height and field measurements.
- D. Installation, Operation, and Maintenance Data: Submit Owner's Manual from manufacturer. Identify with project name, location, and completion date, and type and size of unit installed.

NOTE: Delete the following Article if LEED is not applicable; edit to meet project LEED requirements.

- E. Sustainable Design Submittals (USGBC [LEED®](#)): Refer to Section 01 81 15, LEED Design Requirements.
 - 1. **LEED 2009** (v3) Credits. Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 1 (EA1): Optimize Energy Performance: System
 - b. Materials and Resources (MR) Credits:
 - 1). MR Credit 1.1 (MRc1.1): Building Reuse - Maintain Existing Exterior Walls, Floors and Roof
 - 2). MR Credit 1.2 (MRc1.2): Building Reuse - Maintain Existing Interior Nonstructural Elements
 - 3). MR Credit 2 (MRc2): Construction Waste Management

NOTE: MR Credit 3 below can apply to reusing salvaged Sliding Glass Storefront.

- 4). MR Credit 3: Materials Reuse - 5% (MRc3.1) or 10% (MRc3.2)
 - 5). MR Credit 7 (MRc7): Certified Wood
 - a). Submit percentage of products made from plant materials with a less than 10-year harvest cycle against the total value of building materials on the project.
 - c. Indoor Environmental Quality (EQ) Credits:
 - 1). IEQ Credit 2 (IEQc2): Increased Ventilation - Case 2 - Naturally Ventilated Spaces
 - 2). IEQ Credit 8.1 (IEQc8.1): Daylight & Views - Daylight 75% of Spaces
 - 3). IEQ Credit 8.2 (IEQc8.2): Daylight & Views - Views for 90% of Spaces
 - 2. **LEED v4 for Building Design and Construction (BD&C)** Credits. Complete online LEED forms and submit other required materials as follows:
 - a. Energy and Atmosphere (EA) Credits:
 - 1). EA Credit 2 (EA2): Optimize Energy Performance
 - b. Materials and Resources (MR) Credits:

NOTE: MR Credit 1 below can apply to reusing salvaged Sliding Glass Storefront.

- 1). MR Credit 1 (MRc1): Building Life-Cycle Impact Reduction; Option 3 - Building and Material Reuse
 - c. Indoor Environmental Quality (EQ) Credits:

- 1). EQ Credit 7 (EQc7): Daylight
- 2). EQ Credit 8 (EQc8): Quality Views
- 3). EQ Credit 9 (EQc9): Acoustic Performance
 - a). Submit calculations or measurements for occupant spaces to meet sound transmission class ratings between adjacent spaces and reverberation time requirements within a room.

F. LEED Closeout Documentation:

NOTE: Edit below to meet project LEED requirements.

1. **LEED 2009** (v3). Submit completed LEED™ submittal Worksheet Templates for the following credits:
 - a. EAc1, MRc1.1, MRc1.2, MRc2, MRc3, MRc7, MRc6, IEQc2, IEQc8.1, IEQc8.2
2. **LEED v4** (BD&C). Submit information and documentation to complete LEED™ Worksheet Templates for the following credits:
 - a. EAc2, MRc1, EQc7, EQc8, EQc9

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer capable of providing complete, precision built, engineered, pre-fitted units with a minimum thirty (30) years' experience in the sale of folding-sliding door systems for large openings in the North American market.
 1. Manufacturer to have ISO 9001: 2015 quality management system registration.
 2. Manufacturer to have ISO 14001: 2015 environmental management system registration.
- B. Installer Qualifications: Installer experienced in the installation of manufacturer's products or other similar products for large openings. Installer to provide reference list of at least three (3) projects of similar scale and complexity successfully completed in the last three (3) years.
 1. Installer to be trained and certified by manufacturer.
- C. Single Source Responsibility: Furnish Sliding Glass Storefront system materials from one manufacturer for entire Project.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Comply with manufacturer's instructions and recommendations, Section 01 60 00 requirements, and as follows:
 1. Deliver materials to job site in sealed, unopened cartons or crates.
 - a. Upon receipt, inspect the shipment to ensure it is complete, in good condition and meets project requirements.
 2. Condition wood components to average prevailing relative humidity before installation. Do not subject wood components to extreme nor rapid changes in heat or humidity.
 3. Do not use forced heat to dry out building.
 4. Store flat in a well-ventilated area out of direct sunlight under cover in a clean and dry location, protecting units against weather and defacement or damage from construction activities, especially to the edges of panels.

1.07 FIELD CONDITIONS

- A. Field Measurements: Contractor to field verify dimensions of rough openings (R.O.), stack storage area, [**floor bolt socket locations**] [**and threshold depressions to receive sill.**] Mark field measurements on product drawing submittal.

1.08 WARRANTY

- A. Manufacturer Warranty: Provide Sliding Glass Storefront system manufacturer's standard limited warranty as per manufacturer's published warranty document in force at time of purchase, subject to change, against defects in materials and workmanship.
 - 1. Warranty Period beginning with the earliest of 120 days from Date of Delivery or Date of Substantial Completion:
 - a. Rollers and Insulated Glass Seal Failure: Ten (10) years
 - b. All Other Components Except Screens: Ten (10) years
 - 1). Exception: Five (5) years if NOT installed by manufacturer's specific system approved or certified trained installer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis-of-Design Product by Manufacturer: **NanaWall HSW66** by **NANA WALL SYSTEMS, INC.** (www.nanawall.com)

NANA WALL SYSTEMS, INC.
100 Meadow Creek Drive, Corte Madera, CA 94925
Toll Free (800) 873-5673
Telephone: (415) 383-3148
Fax: (415) 383-0312
Email: info@nanawall.com

- 1. Substitution Procedures: See Section 01 20 00; Submit completed and signed:
 - a. Document 00 43 25, Substitution Request Form (During Procurement), or
 - b. Document 00 63 25, Substitution Request Form (During Construction)

2.02 PERFORMANCE / DESIGN CRITERIA

NOTE: Specify Low Profile Saddle Sills for resistance against wind driven rain.
Flush Sills and Surface Mounted Interior Sills have NO rating against wind driven rain.
Floor Sockets without a Sill do NOT have a water rating.
Weeps are to be drilled in the field by the installer to manufacturer's requirements.
Air infiltration and water penetration testing results are only applicable if the unit matches the tested panel and unit size, direction of opening and type of sill.
Structural load testing results are only applicable for the test unit size and type of locking and rods.
Comparative analysis charts published by manufacturer shows which panel sizes, if any, meets the structural loading design pressures specifically required for the project. Check for limitations on the use of these charts in the jurisdiction of the project.
Forced entry testing results are only applicable for the test unit type of locking.
See manufacturer's latest published data regarding performance.
It is expected that the installed system's performance would be not more than 2/3rds of the following certified laboratory test data in accordance with AAMA 502.

- A. Performance Criteria (Lab Tested):
 - 1. Air Infiltration (ASTM E283): **Low Profile Saddle Sill**
 - a. 0.12 cfm/ft² (0.60 L/s/m²) at a static air pressure difference of 1.56 psf (75 Pa).
 - b. 0.30 cfm/ft² (1.5 L/s/m²) at a static air pressure difference of 6.24 psf (300 Pa).

2. Water Penetration (ASTM E331 and ASTM E547): **Low Profile Saddle Sill**
a. No uncontrolled water leakage at a static test pressure in:
1). Units with Weep holes from Inner Channel: 5.00 psf (240 Pa)
3. Structural Loading (ASTM E330): Pass
a. Load Structure: At 1.5 times design wind load pressure with no glass breakage or permanent damage to fasteners or storefront components.
1). Design Pressure Positive: 41 psf (2000 Pa)
2). Design Pressure Negative: 41 psf (2000 Pa)
4. Forced Entry (AAMA 1304): Meets 300 lb. (1330 N) point load requirement.
5. Sliding Glass Storefront Units tested to AAMA/WDMA/CSA 101/I.S.2/A440.
6. Thermal Performance (U-factor): NFRC 100 Rated, Certified, and Labeled.
7. Solar Heat Gain Coefficient (SHGC) + Visible Light Transmission (VT): NFRC 200 Rated, Certified, and Labeled.
8. Air Leakage: NFRC 400 Rated, Certified, and Labeled.
9. Condensation Resistance Factor (CRF): NFRC 500 Rated, Certified, and Labeled.

NOTE: The NFRC 100, 200, 400 and 500 ratings of the HSW66 Sliding Glass Storefront System meet **Prescriptive Method** requirements for U-factor, SHGC, Air Leakage, and CRF of *California Title 24, Chapter 3, Building Envelope Requirements*.

For the listing of Nana Wall product NFRC testing reports go to the following website <http://search.nfrc.org/search/searchdefault.aspx>; click on **Door** (Find Ratings for Door Products); click on the **Search by Manufacturer** button; click **Manufacturers**, scroll down to and click on **Nana Wall Systems, Inc.**, and click on the **Find Products** button.

10. EPA Energy Star: Meets requirements

NOTE: **Energy Star** values for DOORS with > 50% glass can be achieved through the use of specific glass units meeting the following requirements:

Northern & North-Central Region: ≤ 0.30 U-factor 0.40 SHGC

South-Central & Southern Region: ≤ 0.30 U-factor 0.25 SHGC

Energy Star Air Leakage Rating Requirements (ASTM E283 in accordance with NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440-11):

Window, Sliding Door, or Skylight: ≤ 0.3 cfm/ft² (1.54 L/s/m²)

Swinging Door: ≤ 0.5 cfm/ft² (2.56 L/s/m²)

For guidance only as Nana Wall Systems is not a participant to the Energy Star Program.

B. LEED Characteristics:

1. **LEED 2009** (v3)

- a. EAc1: *NanaWall* systems using low U-Value designed double or triple IGU and thermally broken frames can provide significant energy performance.
- b. MRc1.1: *NanaWall* exterior glass wall systems, not demolished in a renovation project, are reused in the same location.
- c. MRc1.2: *NanaWall* interior glass wall systems, not demolished in a renovation project, are reused in the same location.
- d. MRc2: *NanaWall* cardboard shipping crates are made of 60% recycled material and are 100% recyclable.
- e. MRc3: *NanaWall's* components easily disassemble and reassemble to "Use as salvaged... or reused materials."

- f. MRc7: *NanaWall* system wood doors and doorframes can be FSC-certified.
 - g. IEQc2: *NanaWall* systems provide natural ventilation in the open position, assisting in the 90% required natural ventilation of occupied spaces of ASHRAE 62.1.
 - h. EQc8.1: *NanaWall* glass wall assembly borrowed light brings daylight deeper into the floor plate.
 - i. EQc8.2: *NanaWall* glass wall assemblies provide direct outdoor lines of sight.
2. **LEED v4 for Building Design and Construction (BD&C)**
- a. EAc2: *NanaWall* systems using low U-Value designed double or triple IGU and thermally broken frames can provide significant energy performance.
 - b. MRc1: *NanaWall* can be easily disassembled for salvage and reuse.
 - c. EQc7: *NanaWall* glass wall assembly borrowed light brings daylight deeper into the floor plate.
 - d. EQc8: *NanaWall* glass wall assemblies provide direct outdoor lines of sight.
- C. Design Criteria:
- 1. Sizes and Configurations: As indicated by the drawings for selected number and size of panels, location of swing panels, and location of tracks and stacking bays.
 - 2. Unit Operation: Adjustable sliding type; sliding and swing hardware with top and bottom tracks.
 - 3. Panel Configuration:
 - a. [Straight]
 - b. [Segmented curve]
 - c. [90° angle turn]
 - d. [135° angle turn]
 - e. [Window/ door combination]
 - 4. Stack Storage Configuration:
 - a. [Remote pocket]
 - b. [Jamb wall]
 - c. [Behind swing door]
 - d. [Straight wall]
 - e. [Jamb wall pocket(s)]

NOTE: Sizes and Configurations: <http://www.nanawall.com/products/hsw66/options>
See manufacturer drawings for selected custom dimensions within maximum frame sizes possible as indicated in manufacturer's literature.
See drawings for selected number of panels and configuration.

- 5. Mounting Type: Top-hung
- 6. Panel Type: Multiple unattached
 - a. [with Entry/Egress panel hinged to side jamb.]
 - b. [with Entry/Egress panel attached to last sliding panel going into a stack.]

2.03 MATERIALS

- A. Sliding Glass Storefront Description: Standard top-hung, single-track, interlocking wood-framed sliding glass storefront system that can be pocketed when open and have a swing door hinged off a side jamb. Manufacturer's standard frame and panel profiles, with head track, stacking bays, side jambs, sliding panels, and swing panels with dimensions as shown on Drawings.

1. Provide clear anodized aluminum head track with [**aluminum**] [**wood fascia**] covers on both sides that match finish.
2. Panels and Frames:
 - a. Panels:
 - 1). Single lite.

NOTE: Single lite above is standard; other options below may require an upcharge.
Refer to manufacturer's size chart for glass panel sizes requiring the use of horizontal mullions.

- 2). [Multiple lites with horizontal mullion(s) at height(s) indicated from the bottom of the panel.]
- 3). [Single lite with simulated divided lites in pattern indicated.]
- 4). [Solid wood]
- 5). Panel Size (W x H): As indicated.

NOTE: Maximum panel sizes up to 10' 0" by 3' 3" (3.05 m by 1 m) for swing panels and 4' 6" (1.385 m) wide for sliding panels.
Panels over 8' 4" (2.54 m) high require an intermediate horizontal mullion.

- 6). Rail Depth: 2-5/8 inch (66 mm)
- 7). Top Rail Width: 3-3/4 inch (93 mm)
- 8). Bottom Rail Width:
 - a). 3-3/84 inch (93 mm)
 - b). [Manufacturer's standard kickplate with height indicated.]

NOTE: Indicate kickplate height. Select height between 6 and 12 inches (152 and 305 mm) high.

- b. Frames:
 - 1). Top Track Depth: 3-15/16 inch (100 mm)
 - 2). Top Track Width: 4-1/2 inch (115 mm)
 - 3). Side Jambs Width: 1-9/16 inch (40 mm)

Note: Select from the following Sill Types, edit to suit, and delete those not meeting project requirements:

- c. Sill Type:
 - 1). [Low profile saddle sill (thermally broken)]
 - 2). [Standard flush sill (thermally broken)]
 - 3). [No sill, floor sockets without a floor track]
 - 4). [Surface mounted interior sill for interior application]
 - 5). Finish: Aluminum with a [**clear**] [**dark bronze**] anodized finish
3. Top Track: Aluminum Extrusion with wood clad with thermal isolating polyamide connectors
 - a. Alloy: AlMgSi0.5; 6063-T5 (F-22 - European standard)
 - b. Thickness: 0.078 inch (2.0 mm) nominal
 - c. Finish (AAMA 611): Clear, anodized
4. Wood: Cross-grained, solid, triple laminated wood with mortise and tenon, and glued and pinned corners.

NOTE: FSC Certified wood Sapeli Mahogany is LEED credit qualified. Others available upon request.

- a. Species:
 - 1). [FSC Sapeli Mahogany]
 - 2). [European Pine]
 - 3). [Spruce]
 - 4). [Western Hemlock]
 - 5). [Meranti]
 - 6). [European Oak]

NOTE: Beech, Maple or Cherry are for interior applications only.

- 7). [Beech]
- 8). [Maple]
- 9). [Cherry]
- b. Wood Finish: See Section 09 90 00; Water-based, open pore with
 - 1). [clear sanding sealer for stain.]
 - 2). [base coat applied for paint.]

NOTE: Before installation, field finish units with a minimum two coats for final protective finish.

B. Glass and Glazing:

- 1. Safety Glazing: In compliance with ASTM C1036, ASTM C1048, ANSI Z97.1 and CPSC 16CFR 1201.
 - a. Glass Acoustical Performance (ASTM E413 and ASTM E1332): STC

NOTE: Unlike wet glazing, NanaWall's standard dry glazing method helps reduce instances of seal failure.

- 2. Manufacturer's [**tempered**] [**and**] [**laminated**] glass lites in [**single**] [**double**] [**triple**] insulated glazing units, dry glazed with glass stops on the inside.

NOTE: Select and edit glass type(s) to meet building code, wind-load design, acoustic, bullet resistant and/or security, and other project requirements with other glass available from manufacturer.

Custom layouts with horizontal mullions, simulated divided lites, inserts, and high bottom rails are possible.

Contact NanaWall for availability of other commercial glass types.

- a. Glass Lite / Insulated Glass Unit (IGU):
 - 1). Single: [1/4 inch (6 mm) thick.]
 - 2). Double IGU: [5/16 inch (24 mm) thick.]
 - 3). Triple IGU: [1-1/8 inch (28 mm) thick.]

NOTE: Subparagraphs below are options for Double and Triple IGU items above.

- 4). IGU Fill:
 - a). Air filled
 - b). [Argon filled]
- 5). Glass Lite Type:
 - a). Standard

Note: Items below are options and may require an upcharge.

- b). [Low Iron]
- c). [Solar Bronze]

- d). [Solar Gray]
- e). [Bird Safe]
- 6). Glass Spacers: Manufacturer's standard
 - a). [silver gray finish with capillary tubes]
 - b). [black finish with capillary tubes]
 - c). [silver gray finish without capillary tubes]
 - d). [black finish without capillary tubes]
- 7). IGU Surface:
 - a). Clear
 - b). [Low-E coating on # 2 surface of double IGU]
 - c). [Low-E coating on # 2 and # 4 surface of double IGU]
 - d). [Low-E coating on # 2 and # 5 surface of triple IGU]

C. Locking Hardware and Handles:

NOTE: Select one of the below Main Entry Panel paragraphs WITH or WITHOUT Swing Panels, deleting all others. Edit to suit project requirements.

1. Main Entry Panel(s) for Models WITH a [**Pair of**] Swing Panels: Provide manufacturer's [**Standard lever handles**] or [**Lever handles with return**] on the inside and outside, and a lockset with a lockable latch and multi-point locking with a dead bolt and rods at the top and bottom on primary panel [**only**].
 - a. Rods to be concealed and not edge mounted.
 - b. After turn of key or thumb-turn, depression of handles withdraws latch.
 - c. Lifting of handles engages rods and turn of key or thumb-turn engages deadbolt and operates lock.
 - d. Lever Handle - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Black titanium stainless steel]

NOTE: Handles above are standard; optional handle types below may require an upcharge. Lever handle with return only available in "Brushed satin stainless steel"

- 3). [Copper-nickel stainless steel antiviral and antimicrobial]
 - 4). [Oil rubbed bronze solid brass]
 - 5). [Satin nickel solid brass]
 - 6). [White solid brass]
 - e. Locking:
 - 1). Standard profile cylinder
 - 2). [Adapter for Small Format Interchangeable Core (SFIC)]
2. Main Entry Panel(s) for Models WITH Swing Panel(s): Provide manufacturer's push-pull handles with separate lockset and dead bolt.

NOTE: Copper-nickel finish handle may require an upcharge.

- a. Push-pull handles in a brushed stainless-steel finish and stainless-steel flat handles in a [**brushed satin finish.**] [**black titanium finish.**] [**copper-nickel finish.**]

NOTE: Option below is recommended with a door closer but note that this will not be possible for a swing panel on a Swing-Slide unit.

3. Main Entry Panel(s) for Models WITH [a] Swing Panel(s): No hardware or locking provided by manufacturer; Field installed panic device by Section 08 71 00 prepped for commercial application.

NOTE: Using panic device hardware by others invalidates manufacturer's design wind-load pressure test.

- a. Panic hardware:
 - 1). [Von Duprin 33/35A Series Narrow Stile Rim Exit Device]
4. Sliding Panel to be Opened First for Models WITHOUT a Swing Panel: Provide manufacturer's standard L-shaped handle on the inside, flat handle on the outside and lock set with profile cylinder Operation of lock set is by turn of key from the outside and with a thumb-turn from the inside with a two-point locking hardware operated by 180° turn of the handle.
 - a. L-Shaped Handles - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Black titanium stainless steel]
5. Sliding Panel to be Opened First for Models WITHOUT a Swing Panel: Provide manufacturer's standard flat handle on the inside and on the outside and a lockset with a profile cylinder. Operation of lock set is by turn of key from the outside and from the inside with a two-point locking hardware operated by 180° turn of the handle.

NOTE: Key operation from the inside above may not meet egress requirements.

6. Main Entry Panel: Provide manufacturer's standard flat handle on inside only with concealed two-point locking hardware operated by 180° turn of handle.

NOTE: With option above the main entry panel is operable from inside only and that there is no latch. Other compatible lever, L-shaped, and push-pull handle styles and finishes are available from other suppliers.

7. Secondary Panels: Provide manufacturer's [**Standard flat handles**] [**Removable custodial handles**] and concealed one or two-point locking hardware operated by 180° turn of handle.

NOTE: Flat handles above are standard with removable custodial handles an option that may require an upcharge.

- a. Flat Handle - Finish:
 - 1). Brushed satin stainless steel
 - 2). [Black titanium stainless steel]

NOTE: Handles above are standard; optional handle types below may require an upcharge.

- 3). [Copper-nickel stainless steel antiviral and antimicrobial]
- 4). [Dark brown powder coated]
- 5). [Silver gray powder coated]
8. Handle Height: 41-3/8 inch (105 cm) centered from bottom of panel or as otherwise indicated.
9. Aluminum locking rods with standard fiberglass reinforced polyamide end caps at the bottom (and top on certain panels). Rods to have a stroke of 15/16 inch (24 mm).
10. Additional profile cylinders to be [**Keyed alike.**] [**Keyed differently.**]

- D. Sliding-Swinging Hardware: Provide manufacturer's standard hardware.
1. For each sliding panel, provide two (2) two-three wheeled, sintered bronze (oil impregnated) unidirectional sliding panel carriers with a one-wheeled, polyamide guide roller that is attached to the panels with stainless steel rods.
 - a. Maximum carrying capacity of two carriers on a panel to be 330 lbs. (150 kgs)
 - b. Hinges - Swing Panel:
 - 1). Clear anodized aluminum

NOTE: Finish above is standard; finish option below may require an upcharge.

- 2). [Dark bronze anodized aluminum]

NOTE: The manufacturer's weather stripping is determined at the factory by the direction of swing, the panel configuration, the type of locking and the type of sill.

2. Weather stripping: Manufacturer's double layer EPDM between panels and EPDM gasket, or brush seal between panel and frame, or brush seals with a two-layer fiberglass reinforced polyamide fin attached at both inner and outer edge of bottom of door panels with a recessed sill or on frame for sealing between panels and between panel and frame.

- E. Fasteners: Stainless steel machine screws for connecting frame components.

2.04 FABRICATION

- A. Extruded aluminum head and threshold frame profiles, solid triple-laminated wood side jamb profiles, tracks, stacking bays, with male-female interlocking solid triple-laminated wood panel profiles, hinges, sliding/swinging hardware, locking hardware and handles, glass and glazing and weather stripping components to construct a single track sliding opening glass wall.
1. Wood frame and panel members to be sealed with a clear sand sealer or primer.
 2. Each unit factory pre-assembled and shipped with all components and installation instructions.
 3. Exposed work to be carefully matched to produce continuity of line and design with all joints.
 4. No raw edges visible at joints.

2.05 ACCESSORIES

- A. **Insect Screen:** Fully retractable non-pleated screen made of ultra-strong, UV resistant fiberglass mesh housed in a single cartridge riding on a single track.
1. Basis-of-Design Product by Manufacturer: **The Horizon** by **Wizard Industries, Inc.**

WIZARD INDUSTRIES, INC.

4263 Phillips Ave, Burnaby, BC, Canada V5A 2X4

Toll Free: (888) 949-3667

Telephone: (604) 299-8878

Fax: (604) 299-4496

Email: sales@wizardindustries.com

<https://www.wizardscreens.com/>

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examination and Acceptance of Conditions per Section 01 70 00 and as follows:
1. Carefully examine rough openings with Installer present, for compliance with requirements affecting Work performance.

- a. Verify that field measurements, substrates, tolerances, levelness, plumbness, cleanliness and other conditions are as required by the manufacturer, and ready to receive Work.
 - b. Verify the structural integrity of the header for deflection with live and dead loads limited to the lesser of $L/720$ of the span or 1/4 inch (6 mm). Provide structural support for lateral loads, and both wind load and eccentric load when the panels are stacked open.
2. Proceed with installation only after unsatisfactory conditions have been corrected.
- 3.02 INSTALLATION
- A. General: Install Sliding Glass Storefront system in accordance with the Drawings, approved submittals, manufacturers' recommendations, and installation instructions, and as follows:
1. Properly flash, waterproof and seal around opening perimeter.
 2. Securely attach anchorage devices to rigidly fit frame in place, level, straight, plumb, and square. Install frame in proper elevation, plane and location, and in proper alignment with other work.
 3. When lower track is designed to drain, provide connections to allow for drainage.
 4. Install panels, handles, lockset, screens, weather stripping and other accessories in accordance with manufacturer's recommendations and instructions.
- 3.03 FIELD QUALITY CONTROL
- A. Field Tests and Inspections per Section 01 40 00 of the following:
1. Verify the Sliding Glass Storefront system operates and functions properly. Adjust hardware for proper operation.
- B. Non-Conforming Work: Repair or replace non-conforming work as directed by the Architect; see General and Supplementary Conditions, and Division 01, General Requirements.
- 3.04 CLEANING AND PROTECTION
- A. Keep units closed and protect Sliding Glass Storefront installation against damage from construction activities.
- B. Remove protective coatings and use manufacturer recommended methods to clean exposed surfaces.

END OF SECTION

DISCLAIMER:

Nana Wall Systems, Inc. takes no responsibility for product selection or application, including, but not limited to, compliance with building codes, safety codes, laws, or fitness for a particular purpose. This guide specification is not intended to be verbatim as a project specification without appropriate modifications for the specific use intended and the requirements of a specific construction project.
www.nanawall.com